

CERTIFICATE OF CONSTANCY OF PERFORMANCE

1299 - CPR - 0173

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Pillar fire hydrant, DN 80, PN 16
Type A, outlets 2xB
Type C, outlets 2xB

Pillar fire hydrant, DN 100, PN 16
Type A, outlets 2xB
Type C, outlets 2xB or 2xB + 1xA

assigned for installing into outdoor water pipes for water supply intended for fire extinguishing including water assigned for human consumption, under condition, that used materials, including lubricants, coming into contact with water for human consumption shall comply with the National Regulations in the country of use,

placed on the market under the name of

ROWATER NET S.A., Brailei str., No. 15 C1
120118 Buzau, Romania

and produced in the manufacturing plant

ROWATER NET S.A., Brailei str., No. 15 C1
120118 Buzau, Romania

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 14 384: 2005

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on March 28th, 2017 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

The certificate shall be supported through annual continuous surveillance and reissued after each surveillance. This certificate shall be reissued not later than March 27th, 2019. A new issue of the certificate is conditioned by positive results of the surveillance.



Piešťany March 22nd, 2018



Ing. Dušan HANKO
on behalf of TSU Piešťany, š.p.
Notified Body 1299

097641